

Job Safety Analysis/Risk Assessment/PPE Assessment

Location: Evergreen Lodge		Department: All Departments	Activity/Process being assessed: Working with Electricity
JSA Reference #: FL014		Assessors: Assistant General Manager	
ID	Job Tasks	Potential Hazard	How to Control Hazard
1	Install receptacles, check breakers, check lights	Slips and falls Cuts/scrapes Silica/Drywall Electrical Ladder	Clean, neat work area, plan out lifting/moving of items Employees to wear gloves when handling materials Wear necessary PPEs Panel to be LOTO'ed. All employees to verify zero energy Proper ladder usage, three points of contact, correct ladder type, ladder to be used and inspected daily before use as per manufacturers instructions.
2	Reporting Accidents/Injuries:	None	Immediately report all accidents to Management.
Required Training:			
Required Personal Protective Equipment (PPE):			
Persons Affected: Operator Other Worker (including leased labor) Outside Contractor			

I understand and will adhere to the steps, hazards and controls as described in this JSA.
 I understand that performing steps out of sequence may pose hazards that have not been evaluated, nor authorized.
 I will contact my supervisor prior to continuing work, if the scope of work changes or new hazards are introduced.
 I understand I have the authority and responsibility to stop work I believe to be unsafe.